



Defense-in-Depth and Diversity for Digital Upgrades

Presented at the Regulatory Information Conference (RIC) 2006

Session Th5D Digital Instrumentation & Control March 9, 2006

Raymond C. Torok
Senior Project Manager
Instrumentation & Control
EPRI

Industry Perspective on "D3"

- Software common-mode failure is a legitimate issue for digital upgrades
 - Need to ensure "adequate coping capability"
 - Treated as beyond-design-basis per NRC guidance
- Regulatory uncertainty remains, with chilling effect on plant upgrades
 - Changing interpretations of regulatory guidance
 - Protracted, unpredictable reviews
- Current NRC guidance (deterministic approach of Branch Technical Position HICB-19) is problematic
 - Can require backups that add complexity and cost without improving safety
 - May not address events that are risk-significant
 - Discourages plant upgrades that would enhance safety
 - Requires analysis of events that are not safety-significant



Use of Risk-Insights Would Improve Current Deterministic Approach

- Keep focus on safety show where software has risk significance
- Allow consideration of plant and digital system characteristics that protect against digital failure and digital CCF, e.g.,
 - Data validation
 - Procedures that allow changes to only one channel at a time
 - Operating system "blind" to plant transients
- Allow consideration of risk associated with adding diverse backups (e.g., spurious actions)
- Consistent with updated technical and regulatory trends
- Technical issues can be addressed
 - Digital system failure probabilities
 - Modeling digital equipment in PRA



Deterministic versus Risk-Informed Example 1 – Large Break LOCA

LBLOCA with digital CCF in low pressure injection (LPI)

- Deterministic (BTP-19) method
 - Insufficient time for operator action
 - Credit for leak detection backup (per BTP-19) may not be allowed
 - Diverse actuation of LPI and supporting systems needed as backup
- Application of risk insights would:
 - Consider low probability of digital CCF in LPI system
 - Show LBLOCA concurrent with digital CCF is a negligible contributor to core damage frequency (CDF)
 - Show that a diverse backup for the I&C
 - Would not reduce risk (because large rotating components dominate)
 - Would add complexity and increase probability of spurious actuation

BTP-19 method adds hardware and complexity, with questionable safety benefit




Deterministic versus Risk-Informed Example 2 – Risk-Significant Events from PRA

Deterministic (BTP-19) focus is on SAR events

PRA considers additional beyond-design-basis events

Some risk-significant events are not evaluated using BTP-19 method



Risk-informed method improves coverage of risk significant events



Guideline for Performing Defense-in-Depth and Diversity Assessments for Digital Upgrades ("D3 Guideline" - EPRI 1002835, December 2004)

- EPRI "D3 Guideline" applies "risk insights" to D3 evaluation
- Provides guidance on:
 - When I&C systems are susceptible to digital common cause failure
 - Where D3 in the I&C is of value in the context of the plant design
 - How reliable a digital system needs to be in the nuclear plant context
- Does not attempt to:
 - Identify all the possible digital system failure modes
 - Precisely determine digital failure probabilities
 - Develop detailed models of digital systems for use in PRA

Nor do we believe these are generally necessary for D3 evaluation



Risk Insights – When is D3 of value for a digital I&C system?

- Dictated by:
 - Frequency of the initiating event
 - Existing D3 of the mechanical and electrical mitigating systems
- High frequency events benefit most from D3 in I&C (e.g., Turbine Trip, Loss of FW)
 - Plant has multiple, diverse mitigating systems
 - Want to preserve existing diversity of electrical / mechanical equip.
- Low frequency events receive little benefit from adding diversity in the I&C (e.g., LOCAs, MSLB)
 - Typically single mitigating system with little diversity between redundant trains of electrical / mechanical equipment

Risk Insights – How reliable does a digital I&C system need to be?

- High frequency events benefit most from reliable I&C
 - Reliability of a channel of digital I&C needs to be similar to that of a functionally similar channel of analog I&C
 - Some degree of diversity needed in actuating mitigating systems (e.g., operator can implement EOPs independent of digital failure)
- For low frequency events, risk is insensitive to reliability of the I&C
 - Usually a single mitigating system with failure probability dominated by major rotating equipment
 - Even assuming CCF of I&C in redundant channels (beta = 1) doesn't make I&C dominant
 - Adding diverse backup for digital I&C has negligible impact on safety

Conclusions/Recommendations

- BTP-19 is out of date and needs improvement
- More balanced design and licensing decision making would help
 - Rule-based (prescriptive) vs. performance-based, e.g.,
 - Could require RPS and ESFAS to be separate and diverse, but for most plants this is unnecessary, because neither backs up the other
 - Better to focus on the real requirement (misbehavior of one system shall not disable another safety function when it's needed)
 - Programmatic (process-based) vs. product or performance-based
 - Could focus primarily on software development process, but good process does not ensure high dependability or safety
 - Better to also consider actual design characteristics and system behaviors, which are more directly linked to dependability and safety

Conclusions/Recommendations, cont'd

- Risk insights should be applied in D3 evaluation
 - Would improve ability to manage safety issues associated with CCFs
 - Can estimate reliability of digital equipment well enough for D3 evaluations **now**, based on deterministic evaluation of the software
 - Can derive useful risk insights for D3 evaluations <u>now</u>
 - Without precise knowledge of failure probabilities
 - Without detailed PRA modeling of digital I&C
 - Future research by RES and others will improve methods, accuracy
 - Software reliability
 - Modeling digital systems in PRA
- More and better coordination between NRC and industry is essential for timely resolution of D3 issues

